

ADDENDUM NUMBER 2

City of Hastings
Engineering Department
1228 N. Denver Ave
Hastings, NE 68901

PROJECT:
CH 2020-09 FC-01 Parkview Cemetery Paving, Phase I

ADDENDUM NUMBER 2

Date: September 15, 2020

Project No.: CH 2020-09 FC-01

Parkview Cemetery Paving, Phase I

Clarification #5: Centerline longitudinal joints shall have No. 5x 2'-6" tie bars on approximately 2'-9" centers and shall be subsidiary to the unit bid price of build 6" PCC Pavement 47B-3500.

The undersigned bidder hereby certifies that the revisions set forth in this addendum have been incorporated in their bid and are part of the contract documents. **Please use and submit this sheet with your proposal.**

Signed _____

Title _____

Firm _____

Date _____