

ELECTRICAL PANEL UPGRADE-A STREET BUILDING

ADDENDUM NO. 1

March 4, 2025

Contract No. CH 2025-11

This addendum forms part of the Contract Documents and modifies the original Bidding Documents as noted below. This addendum consists of the following:

Addenda:

- *On Drawing E-OH-592.1, the “Sign Shop 100 Amp 1Ø 120/240 MLO” panel is not labeled as existing but should be. It is our intent that the existing duct, wire and panel will remain in place and feed from a new breaker in the new main panel.*
- *New “Panel 2” can be eliminated if the new “Main Panel” will have plenty of breaker spaces.*
- *It is our expectation that all items, which are existing items, shown on drawing E-OH-592.3 will be removed.*

CITY OF HASTINGS

By Tyler Waite

Title Coordinating Engineer

The undersigned bidder hereby certifies that the revision set forth in this addendum have been incorporated in their bid and are a part of the contract documents.

Signed _____

Title _____

Firm _____

Date _____

**ALL ISSUED ADDENDUM(S) MUST BE ACKNOWLEDGED
& RETURNED WITH YOUR BID DOCUMENTS**