

CITY OF HASTINGS

ADDENDUM NO. 1

5/30/2025

HASTINGS SOUTHEAST WATER MAIN IMPROVEMENT PHASE 1

Contract No. HU 2025-79

Add the following Specification Section:

4.118: Plastic Service Line Encasement.

a. Materials: HDPE 4710 conforming to ASTM D3350.

b. Sizing: encasement shall be two nominal pipe sizes larger than pipe being encased, minimum of 2" greater than outside diameter.

<i>Water Service (in.)</i>	<i>Casing Diameter (in.)</i>	<i>Rating</i>
<i>1"</i>	<i>3"</i>	<i>SDR 13.5</i>
<i>2"</i>	<i>4"</i>	<i>SDR 17</i>

CITY OF HASTINGS

By Keith Miller, P.E.

Title Engineer

The undersigned bidder hereby certifies that the revision set forth in this addendum have been incorporated in their bid and are a part of the contract documents.

Signed _____

Title _____

Firm _____

Date _____

**ALL ISSUED ADDENDUM(S) MUST BE ACKNOWLEDGED
& RETURNED WITH YOUR BID DOCUMENTS**