NDS BOILERFRONT PLATFORMS
CITY OF HASTINGS

ADDENDUM NO. 1

May 9, 2025

Contract No. HU 2025-68

This addendum forms part of the Contract Documents and modifies the original Bidding Documents as noted below. This addendum consists of the following:

Addenda:

- *The horizontal beams of the Unit 4 Boilerfront platform, except the horizontal beams at the two ladders, shall be HSS3x3x3/8 as shown in the attached drawing.*
- *The paint color of handrails shall be Safety Yellow.*
- *All other steel shall be shop-primed gray/silver OR shop-primed and painted gray/silver. The final coat must be gray or silver to match existing.*
- *Paint shall be Sherwin Williams Industrial Enamel VOC Alkyd Gloss Enamel B54-Z100 Series or equivalent*

CITY OF HASTINGS

By ***Carson Moritz***

Title Mechanical Engineer

The undersigned bidder hereby certifies that the revision set forth in this addendum have been incorporated in their bid and are a part of the contract documents.

Signed _____

Title _____

Firm _____

Date _____

ALL ISSUED ADDENDUM(S) MUST BE ACKNOWLEDGED & RETURNED WITH YOUR BID DOCUMENTS

NDS BOILERFRONT PLATFORMS
CITY OF HASTINGS

ADDENDUM NO. 1

May 9, 2025

Contract No. HU 2025-68

