

**CONTRACT AND SPECIFICATIONS  
TO  
FURNISH STEEL GAS PIPE  
FOR  
CITY OF HASTINGS, NEBRASKA**

**Contract No. HU 2025-58**

**Sealed Proposals Will Be Opened Promptly At  
1:30 PM, Wednesday, April 16, 2025**

**Bid Submitted By:** \_\_\_\_\_



## ADVERTISEMENT FOR BIDS

The City of Hastings, Nebraska, will receive bids to: **Furnish Steel Gas Pipe HU 2025-58** for the City of Hastings until 1:30 p.m. at the City of Hastings, 1228 N Denver Ave., Hastings, Nebraska, on Wednesday, April 16, 2025, at which time and place all bids will be publicly opened and read aloud. **Brief description of project: Furnish Steel Gas Pipe for the City of Hastings in Hastings, Nebraska.** If you plan on bidding and are not already on our approved bidders list for this project, you are REQUIRED to fill out the [Plan Holders Submittal Form](https://www.cityofhastings.org/bids/) that is located on the City website: <https://www.cityofhastings.org/bids/>.

No bid shall be withdrawn after opening of bids without the consent of the City of Hastings, Nebraska, for a period of sixty (14) days after scheduled time of closing bids.

Time is of the essence in this contract. In evaluating bid(s) received, the City will consider the timelines of completion of prior construction contracts, existing workload of bidders and available manpower that bidder commits to the project.

DATED AT HASTINGS, NEBRASKA, this 28th day of March 2025.

CITY OF HASTINGS, NEBRASKA

---

Tyler Ficken, City Clerk

Publish:  
April 1, 2025  
April 8, 2025

Furnish 2 proofs of publication

**FURNISH STEEL GAS PIPE  
CONTRACT NO. HU 2025-58**

**IF YOU HAVE QUESTIONS OR  
NEED HELP ON THESE SPECIFICATIONS  
PLEASE CONTACT ANY OF THE FOLLOWING:**

**General Questions**

Carson Moritz  
Mechanical Engineer  
Ph# 402-462-3678  
Email: [bidquestions@cityofhastings.org](mailto:bidquestions@cityofhastings.org)

Zach McCartney  
Storekeeper  
Ph# 402-462-3647  
Email: [bidquestions@cityofhastings.org](mailto:bidquestions@cityofhastings.org)

Rena Griess  
Engineering Admin Assistant  
Ph# 402-462-3665  
Email: [bidquestions@cityofhastings.org](mailto:bidquestions@cityofhastings.org)



# IMPORTANT MAILING OR HAND DELIVERY INSTRUCTIONS


PLEASE ADDRESS YOUR RETURN ENVELOPE  
AS SHOWN IN THE EXAMPLE BELOW

To hand deliver, please drop off between the hours of 8:00am – 5:00pm Monday-Friday

Your Return Address

Attn: Renae Griess  
City of Hastings  
1228 N Denver Ave  
Hastings, NE 68901

**This Information MUST BE typed or written in the lower left hand corner of return envelope, or simply cut out & tape on your return envelope whether mailed or hand delivered.**



**IMPORTANT BID DOCUMENTS ENCLOSED**  
**Attn: Renae Griess**  
**Contract No. HU 2025-58**  
**Furnish Steel Gas Pipe**  
**Bid Opening: Wednesday, April 16, 2025**  
**Time: 1:30 PM**

IF RETURNING BY OVER NIGHT OR NEXT DAY AIR  
YOUR BID MUST BE ENCLOSED IN AN “INNER” ENVELOPE  
WHICH IS SEALED AND PROPERLY MARKED ON THE  
OUTSIDE OF BOTH ENVELOPES

## INSTRUCTIONS TO BIDDERS

All proposal information, including any unit price fill in sheets or other required information, shall be submitted on the proposal forms hereto attached. Copies of addenda, if any, shall be signed and attached. City of Hastings does NOT accept faxed or emailed bid returns.

Bidders shall inform themselves of all relevant matters, and, if awarded the contract, shall not be allowed any extra compensation by reason of any matter or thing concerning which such Bidder might not have fully informed himself, prior to the bidding.

The Bidder bidding on the Specifications herein, who has exceptions to those called for in the Specifications, must so state in the space provided below and/or attach a letter explaining in detail the exceptions taken to those required in the Specifications. This letter of explanation shall become a part of the bid and shall be attached hereto. Failure by the Bidder to outline his exceptions will require the successful Bidder to comply with these Specifications.

EXCEPTIONS TO SPECIFICATIONS:

---

---

---

---

---

---

The City will not assume obligations resulting from losses or damages until acceptance of the equipment.

If any person contemplating submitting a bid for this contract is in doubt as to the true meaning of any part of the Specifications or other proposed contract documents, he may submit to Purchaser a written request for an interpretation thereof. The person submitting the request will be responsible for its prompt delivery. Any interpretation of the proposed documents will be made only by addendum duly issued or delivered to each person receiving a set of such documents. The Purchaser will not be responsible for any other explanation or interpretation of the proposed documents.

All addendums must be signed and attached to bid documents.

**PROPOSAL TO FURNISH STEEL GAS PIPE**  
**Contract No. HU 2025-58**

City of Hastings  
 1228 N Denver Ave  
 Hastings, NE 68901

**Return Date on or Before: 4/16/2025    Wednesday @ 1:30 PM**

Bidders:

We, the undersigned, being familiar with all parts of this Proposal, including Specifications, do hereby submit our proposal to **furnish and deliver f.o.b., Hastings Utilities Warehouse, 1112 S Elm Ave, Hastings, Nebraska**, the following materials for the following price:

Item	Quantity		Description	Unit Price	Total Price
1.	80	ft	4" Steel Pipe	\$	\$
2.	1920	ft	8" Steel Pipe		
3.	4	ea.	4" 90 EH Weld Ell		
4.	15	ea.	8" 90 EH-LR Weld Ell		
5.	5	ea.	8" Segmented 90 Weld Ell		
Subtotal					\$
Total City & State Sales Tax @ 7.0%					\$
Total Price _____					\$
(In Words)					

In submitting this proposal, it is understood that the City of Hastings reserves the right to reject any or all proposals, and it is further understood that this proposal may not be withdrawn for a period of fourteen (14) days after bids are opened.

List and state any and all variations from and exceptions to the requirements of the bid specifications.

Pipe shall be delivered to **1112 S Elm Ave, Hastings NE, 68901. Contact Zach McCartney, Lead Storekeeper at 402-462-3647 to make delivery arrangements.**

**PROPOSAL TO FURNISH STEEL GAS PIPE**  
**Contract No. HU 2025-58**

The quote prices (on page 1 of 2) are firm and include all taxes which might be assessed against the owner or the bidder on the date of this proposal.

Exceptions: No  Yes  (If yes, list separately on Instructions to Bidders page)

**All bid documents must be submitted with original signatures. No copies will be accepted.**

**OFFICIAL NAME & ADDRESS**

Firm Name	Signature
Address	Typed or Printed Name
City, State, Zip	Title
Phone No.	Date
Fax No.	Email Address

**PROPOSAL  
FOR  
FURNISHING STEEL GAS PIPE  
Contract No. HU 2025-58**

**PROPOSAL DATA**

	<b>PIPE SIZE</b>	
	<b>4"</b>	<b>8"</b>
Pip Manufacturer		
Pipe O.D.		
Pipe Wall Thickness		
Pipe Specifications		
No. & Grade		
Coating Type		
Coating Number		
Coating Thickness		
Coating Manufacturer		
Coating Applicator		

# **GENERAL CONDITIONS**

## **GC.1 PROPOSAL DOCUMENTS**

It is understood and agreed that the Notice to Bidders, Instructions to Bidders, Proposal, Proposal Data, General Conditions, Specifications, Drawings, Addenda, and Change Orders issued by the Owner, and specifications and engineering data furnished by the Supplier and accepted by the Owner, are each included in this Proposal and the work shall be done in accordance therewith.

## **GC.2 ENGINEERING INSPECTION**

The Owner may appoint such inspectors as he deems proper to inspect the materials furnished and the work performed for compliance with the specifications. This includes inspection of the coating application process. The Supplier shall furnish all reasonable assistance required by the inspector including adequate notice for the proper inspection of the work. Should the Supplier object to any order given by the inspector, he shall make written appeal to the Owner for a decision.

## **GC.3 GUARANTEE**

The Supplier shall guarantee the materials and workmanship furnished under this Proposal to be as specified and to be free from defects for a period of one year after the date of final payment. Upon notification, the Supplier shall promptly make all repairs or replacement which in the opinion of the Owner arose out of defects and became necessary during the guarantee period. The cost of all materials, labor, transportation, supervision, special tools, and supplies required for repair of defects shall be paid by the Supplier.

This Guarantee shall be extended to cover all repairs and replacements furnished under the guarantee and the period of the guarantee for each such repair or replacement shall be one year after installation or completion.

In the event of an emergency where, in the judgment of the Owner, delay would cause serious loss or damage, repairs or adjustments may be made by the Owner, or a third party chosen by the Owner, without advance notice to the Supplier and the cost of the work shall be paid by the Supplier.

**CITY OF HASTINGS SPECIFICATIONS  
FOR  
STEEL GAS PIPE**

1. All 2” through 6” steel pipe shall be API 5L Grade B or X42 PSL1 and 8" and 10" which shall be API 5L Grade X42 PSL1. Suppliers may supply pipe that is double or triple stamped, meaning that is qualifies for multiple API 5L grades. All pipe shall be Schedule 40 except 8", which shall have a wall thickness of .188; and 10", which shall have a wall thickness of .250". Sixteen inch (16") casing pipe shall be .250" wall thickness and grade B. Pipe shall be new domestic pipe. All pipe shall be seamless (SMLS) or electric-resistance welded (ERW).
2. The outside coating shall be fusion bond epoxy for all sizes of pipe. Fusion bond epoxy coating shall be 14 -16 mils. Fusion bond epoxy shall meet the requirements of the current version of NACE SP0394 Application, Performance, and Quality Control of Plant-Applied Single-Layer Fusion-Bonded Epoxy External Pipe Coating. Cut-back of all plant-applied coatings shall be 2-3 inches.
3. All pipe must have beveled ends for welding.
4. All larger size pipe shall be 40 ft. double random lengths.
5. All pipe shall be protected from damage to the coating or pipe during transportation.
6. Any suspected inferior coating, damage to the pipe, or unacceptable amount of material inside pipe when inspected will cause the pipe to be rejected both prior to unloading or after unloading. Cause for rejection of pipe shall include greater than two holidays per pipe length; except 1" pipe, which shall be one holiday per pipe length. Hastings Utilities will jeep fusion bond epoxy coated pipe prior to acceptance to NACE RP0490 Holiday Detection of Fusion-Bonded Epoxy External Pipeline Coatings of 10 to 30 mils.
7. All damaged pipe will be replaced or the damage acceptably repaired by the supplier before placement in permanent stock pipe at Hastings Utilities pipe yard.
8. No payment will be made prior to acceptance by Hastings Utilities.
9. Delivery will be f.o.b. Hastings, Nebraska to a staging area located at 1112 S Elm Ave, Hastings, NE.
10. A specific delivery appointment must be scheduled a minimum of 24 hours prior to delivery. Contact information for delivery appointment scheduling will be Zach McCartney, Lead Storekeeper, (Ph# 402-462-3647). Only two loads of pipe can be unloaded within an 8 hour period.

**CITY OF HASTINGS SPECIFICATIONS  
FOR  
STEEL GAS PIPE**

11. The supplier shall send H.U. a copy of mill test reports for all pipe which shall include information on pipe grade, hydrostatic test pressure, yield strength, tensile strength, chemical makeup, and quantity shipped.
12. The pipe shall be stamped with the following: Type, grade, heat number, size, material, manufacturer.